



REPORT NUMBER R009647

**Emission Testing Report
Enwave Central Park Pty Ltd, Chippendale**

Document Information

Template Version; 030620

Client Name: Enwave Central Park Pty Ltd
Report Number: R009647
Date of Issue: 18 September 2020
Attention: Atiq Rehman
Address: 2 Chippendale Way
Chippendale NSW 2008
Testing Laboratory: Ektimo Pty Ltd, ABN 86 600 381 413

Report Authorisation



Hamish Proust
Client Manager

NATA Accredited Laboratory
No. 14601

Glenn Trenear
Ektimo Signatory

Accredited for compliance with ISO/IEC 17025 - Testing. NATA is a signatory to the ILAC mutual recognition arrangement for the mutual recognition of the equivalence of testing, calibration and inspection reports.

This document is confidential and is prepared for the exclusive use of Enwave Central Park Pty Ltd and those granted permission by Enwave Central Park Pty Ltd.

The report shall not be reproduced except in full.

Please note that only numerical results pertaining to measurements conducted directly by Ektimo are covered by Ektimo's terms of NATA accreditation. This does not include comments, conclusions or recommendations based upon the results. Refer to 'Test Methods' for full details of testing covered by NATA accreditation.

Table of Contents

1	Executive Summary	4
1.1	Background.....	4
1.2	Project Objectives	4
1.3	Results Summary.....	4
2	Results	5
2.1	EPA ID No.1 – Engine 1.....	5
2.2	EPA ID No.2 – Engine 2.....	6
3	Plant Operating Conditions	7
4	Test Methods	7
5	Quality Assurance/Quality Control Information	7
6	Definitions	8

1 EXECUTIVE SUMMARY

1.1 Background

Ektime was engaged by Enwave Central Park Pty Ltd to perform emission testing at their Chippendale plant. Testing was carried out in accordance with NSW EPA Environment Protection Licence 20768.

1.2 Project Objectives

The objectives of the project were to conduct a monitoring programme to quantify emissions from two discharge points to determine compliance with Enwave Central Park Pty Ltd's Environment Protection Licence.

Monitoring was performed as follows:

Location	Test Date	Test Parameters*
EPA ID No.1 – Engine 1	13 August 2020	Nitrogen oxides (as NO ₂)
EPA ID No.2 – Engine 2		Carbon dioxide
		Oxygen
		Ammonia

* Flow rate, velocity, temperature and moisture were also determined.

All results are reported on a dry basis at STP.

Plant operating conditions have been noted in the report.

1.3 Results Summary

The following licence comparison table shows that all analytes highlighted in green are within the licence limit set by the NSW EPA as per licence 20768 (last amended on 18 April 2016).

EPA No.	Location Description	Pollutant	Units	Licence Limit	Detected Values
1	Engine 1	Nitrogen Oxides	mg/m ³	57	23
		Ammonia	mg/m ³	4	<0.006
2	Engine 2	Nitrogen Oxides	mg/m ³	57	50
		Ammonia	mg/m ³	4	<0.006

Please note that the measurement uncertainty associated with the test results was not considered when determining whether the results were compliant or non-compliant.

Refer to the Test Methods table for the measurement uncertainties.

2 RESULTS

2.1 EPA ID No.1 – Engine 1

Date	13/08/2020	Client	Enwave Central Park Pty Ltd
Report	R009647	Stack ID	EPA ID No. 1 - Engine 1
Licence No.	20768	Location	Chippendale
Ektime Staff	Hamish Proust	State	NSW
Process Conditions	Engine Load: 40%, SCR Temp: 432°C		

200805

Sampling Plane Details

Sampling plane dimensions	430 mm
Sampling plane area	0.145 m ²
Sampling port size, number & depth	1" BSP (x2), 60 mm
Access & height of ports	Stairs 1.5 m
Duct orientation & shape	Vertical Circular
Downstream disturbance	Bend 7 D
Upstream disturbance	Bend 6 D
No. traverses & points sampled	2 8
Sample plane compliance to AS4323.1	Ideal

Stack Parameters

Moisture content, %v/v	12	
Gas molecular weight, g/g mole	28.2 (wet)	29.5 (dry)
Gas density at STP, kg/m ³	1.26 (wet)	1.32 (dry)

Gas Flow Parameters

Flow measurement time(s) (hhmm)	1250 & 1358
Temperature, °C	105
Temperature, K	378
Velocity at sampling plane, m/s	9.7
Volumetric flow rate, actual, m ³ /s	1.4
Volumetric flow rate (wet STP), m ³ /s	1
Volumetric flow rate (dry STP), m ³ /s	0.9
Mass flow rate (wet basis), kg/hour	4600
Velocity difference, %	-7

Gas Analyser Results		Average		Minimum		Maximum	
	Samplingtime	1255 - 1355		1255 - 1355		1255 - 1355	
Combustion Gases		Concentration	Mass Rate	Concentration	Mass Rate	Concentration	Mass Rate
		mg/m³	g/min	mg/m³	g/min	mg/m³	g/min
	Nitrogen oxides (as NO₂)	23	1.3	4.5	0.24	81	4.4
		Concentration		Concentration		Concentration	
		%v/v		%v/v		%v/v	
	Carbon dioxide	6.3		6.2		6.4	
	Oxygen	9.6		9.5		9.7	

Ammonia	Sampling time	Results 1255-1355	
		Concentration mg/m ³	Mass Rate g/min
Ammonia		<0.006	<0.0003

2.2 EPA ID No.2 – Engine 2

Date	13/08/2020	Client	Enwave Central Park Pty Ltd
Report	R009647	Stack ID	EPA ID No. 2 - Engine 2
Licence No.	20768	Location	Chippendale
Ektimo Staff	Hamish Proust	State	NSW
Process Conditions	Engine Load: 48.5%, SCR Temp: 425°C		

200805

Sampling Plane Details

Sampling plane dimensions	430 mm
Sampling plane area	0.145 m ²
Sampling port size, number & depth	1" BSP (x2), 60 mm
Access & height of ports	Stairs 1.5 m
Duct orientation & shape	Vertical Circular
Downstream disturbance	Bend 7 D
Upstream disturbance	Bend 6 D
No. traverses & points sampled	2 8
Sample plane compliance to AS4323.1	Ideal

Stack Parameters

Moisture content, %v/v	8.9	
Gas molecular weight, g/g mole	28.4 (wet)	29.5 (dry)
Gas density at STP, kg/m ³	1.27 (wet)	1.31 (dry)

Gas Flow Parameters

Flow measurement time(s) (hhmm)	1105 & 1218
Temperature, °C	112
Temperature, K	385
Velocity at sampling plane, m/s	9.7
Volumetric flow rate, actual, m ³ /s	1.4
Volumetric flow rate (wet STP), m ³ /s	1
Volumetric flow rate (dry STP), m ³ /s	0.91
Mass flow rate (wet basis), kg/hour	4600
Velocity difference, %	8

Gas Analyser Results		Average		Minimum		Maximum	
	Samplingtime	1111 - 1211		1111 - 1211		1111 - 1211	
Combustion Gases		Concentration	Mass Rate	Concentration	Mass Rate	Concentration	Mass Rate
		mg/m³	g/min	mg/m³	g/min	mg/m³	g/min
	Nitrogen oxides (as NO₂)	50	2.7	18	1	70	3.8
		Concentration		Concentration		Concentration	
		%v/v		%v/v		%v/v	
	Carbon dioxide	5.9		5.7		6.1	
	Oxygen	9.8		9.7		9.8	

Ammonia	Sampling time	Results 1115-1215	
		Concentration mg/m ³	Mass Rate g/min
Ammonia		<0.006	<0.0003

3 PLANT OPERATING CONDITIONS

Engine parameters have been noted in the results section of the report.

4 TEST METHODS

All sampling and analysis performed by Ektimo unless otherwise specified. Specific details of the methods are available upon request.

Parameter	Sampling Method	Analysis Method	Uncertainty*	NATA Accredited	
				Sampling	Analysis
Sample plane criteria	NSW TM-1	NA	NA	✓	NA
Flow rate, temperature and velocity	NA	NSW TM-2	8%, 2%, 7%	NA	✓
Moisture content	NSW TM-22	NSW TM-22	19%	✓	✓
Carbon dioxide	NSW TM-24	NSW TM-24	13%	✓	✓
Nitrogen oxides	NSW TM-11	NSW TM-11	12%	✓	✓
Oxygen	NSW TM-25	NSW TM-25	13%	✓	✓
Ammonia	Ektimo 260	Envirolab Inorg-093	18%	✓	✓ [†]

200124

* Uncertainty values cited in this table are calculated at the 95% confidence level (coverage factor = 2)

[†] Analysis performed by Envirolab, NATA accreditation number 2901. Results were reported on 24 August 2020 in report number 249231.

5 QUALITY ASSURANCE/QUALITY CONTROL INFORMATION

Ektimo is accredited by the National Association of Testing Authorities (NATA) for the sampling and analysis of air pollutants from industrial sources. Unless otherwise stated test methods used are accredited with the National Association of Testing Authorities. For full details, search for Ektimo at NATA's website www.nata.com.au.

Ektimo is accredited by NATA (National Association of Testing Authorities) to ISO/IEC 17025 - Testing. ISO/IEC 17025 - Testing requires that a laboratory have adequate equipment to perform the testing, as well as laboratory personnel with the competence to perform the testing. This quality assurance system is administered and maintained by the Quality Director.

NATA is a member of APLAC (Asia Pacific Laboratory Accreditation Co-operation) and of ILAC (International Laboratory Accreditation Co-operation). Through the mutual recognition arrangements with both of these organisations, NATA accreditation is recognised worldwide.

6 DEFINITIONS

The following symbols and abbreviations may be used in this test report:

% v/v	Volume to volume ratio, dry or wet basis
~	Approximately
<	Less than
>	Greater than
≥	Greater than or equal to
APHA	American public health association, Standard Methods for the Examination of Water and Waste Water
AS	Australian Standard
BSP	British standard pipe
CARB	Californian Air Resources Board
CEM	Continuous Emission Monitoring
CEMS	Continuous Emission Monitoring System
CTM	Conditional test method
D	Duct diameter or equivalent duct diameter for rectangular ducts
D ₅₀	'Cut size' of a cyclone defined as the particle diameter at which the cyclone achieves a 50% collection efficiency ie. half of the particles are retained by the cyclone and half are not and pass through it to the next stage. The D ₅₀ method simplifies the capture efficiency distribution by assuming that a given cyclone stage captures all of the particles with a diameter equal to or greater than the D ₅₀ of that cyclone and less than the D ₅₀ of the preceding cyclone.
DECC	Department of Environment & Climate Change (NSW)
Disturbance	A flow obstruction or instability in the direction of the flow which may impede accurate flow determination. This includes centrifugal fans, axial fans, partially closed or closed dampers, louvres, bends, connections, junctions, direction changes or changes in pipe diameter.
DWER	Department of Water and Environmental Regulation (WA)
DEHP	Department of Environment and Heritage Protection (QLD)
EPA	Environment Protection Authority
FTIR	Fourier Transform Infra-red
ISC	Intersociety committee, Methods of Air Sampling and Analysis
ISO	International Organisation for Standardisation
Lower Bound	Defines values reported below detection as equal to zero.
Medium Bound	Defines values reported below detection are equal to half the detection limit.
NA	Not applicable
NATA	National Association of Testing Authorities
NIOSH	National Institute of Occupational Safety and Health
NT	Not tested or results not required
OM	Other approved method
OU	The number of odour units per unit of volume. The numerical value of the odour concentration is equal to the number of dilutions to arrive at the odour threshold (50% panel response).
PM ₁₀	Atmospheric suspended particulate matter having an equivalent aerodynamic diameter of less than approximately 10 microns (µm).
PM _{2.5}	Atmospheric suspended particulate matter having an equivalent aerodynamic diameter of less than approximately 2.5 microns (µm).
PSA	Particle size analysis
RATA	Relative Accuracy Test Audit
Semi-quantified VOCs	Unknown VOCs (those not matching a standard compound), are identified by matching the mass spectrum of the chromatographic peak to the NIST Standard Reference Database (version 14.0), with a match quality exceeding 70%. An estimated concentration will be determined by matching the integrated area of the peak with the nearest suitable compound in the analytical calibration standard mixture.
STP	Standard temperature and pressure. Gas volumes and concentrations are expressed on a dry basis at 0°C, at discharge oxygen concentration and an absolute pressure of 101.325 kPa, unless otherwise specified.
TM	Test Method
TOC	The sum of all compounds of carbon which contain at least one carbon to carbon bond, plus methane and its derivatives.
USEPA	United States Environmental Protection Agency
VDI	Verein Deutscher Ingenieure (Association of German Engineers)
Velocity Difference	The percentage difference between the average of initial flows and afterflows.
Vic EPA	Victorian Environment Protection Authority
VOC	Any chemical compound based on carbon with a vapour pressure of at least 0.010 kPa at 25°C or having a corresponding volatility under the particular conditions of use. These compounds may contain oxygen, nitrogen and other elements, but specifically excluded are carbon monoxide, carbon dioxide, carbonic acid, metallic carbides and carbonate salts.
XRD	X-ray Diffractometry
Upper Bound	Defines values reported below detection are equal to the detection limit.
95% confidence interval	Range of values that contains the true result with 95% certainty. This means there is a 5% risk that the true result is outside this range.



Address (Head Office)
7 Redland Drive
Mitcham VIC 3132

Postal Address
52 Cooper Road
Cockburn Central WA 6164

Office Locations
VIC NSW WA QLD

Freecall: 1300 364 005
www.ektimo.com.au
ABN 86 600 381 413