

**CPE Central Park Pty Ltd, Chippendale**  
**Emission Testing Report**  
**Report Number R014619**

---

## Document Information

Template Version 130223

Client Name: CPE Central Park Pty Ltd  
Report Number: R014619  
Date of Issue: 9 June 2023  
Attention: JP Ricafuente  
Address: 3 Central Park Ave  
Chippendale NSW 2234  
Testing Laboratory: Ektimo Pty Ltd, ABN 86 600 381 413

## Report Authorisation



**Graham Edwards**  
Senior Air Monitoring  
Consultant



NATA Accredited Laboratory  
No. 14601

Accredited for compliance with ISO/IEC 17025 - Testing. NATA is a signatory to the ILAC mutual recognition arrangement for the mutual recognition of the equivalence of testing, calibration, and inspection reports.

This document is confidential and is prepared for the exclusive use of CPE Central Park Pty Ltd and those granted permission by CPE Central Park Pty Ltd. The report shall not be reproduced except in full.

*Please note that only numerical results pertaining to measurements conducted directly by Ektimo are covered by Ektimo's terms of NATA accreditation as described in the Test Methods table. This does not include calculations that use data supplied by third-parties, comments, conclusions, or recommendations based upon the results. Refer to 'Test Methods' for full details of testing covered by NATA accreditation.*

## Table of Contents

1	Executive Summary .....	4
1.1	Background .....	4
1.2	Project Objective & Overview .....	4
1.3	Licence Comparison .....	4
2	Results .....	5
2.1	EPA ID No. 1 - Engine 1 .....	5
2.2	EPA ID No. 2 - Engine 2 .....	6
3	Plant Operating Conditions .....	7
4	Test Methods.....	7
4.1	Deviations to Test Methods .....	7
5	Quality Assurance/Quality Control Information .....	8
6	Definitions .....	8
7	Appendices .....	9
7.1	Appendix 1: Chain of Custody	
7.2	Appendix 2: Laboratory Results	

## 1 Executive Summary

### 1.1 Background

Ektimo was engaged by Clean Peak Energy (CPE) Central Park Pty Ltd to perform emission testing at their Chippendale plant. Testing was carried out in accordance with Environmental Licence 20768.

### 1.2 Project Objective & Overview

The objective of the project was to conduct a monitoring programme to quantify emissions from two (2) discharge points to determine compliance with CPE's Environment Protection Licence.

Monitoring was performed as follows:

Location	Test Date	Test Parameters*
EPA ID No. 1 - Engine 1	09 May 2023	Nitrogen Oxides (as NO <sub>2</sub> )
EPA ID No. 2 - Engine 2		Ammonia (NH <sub>3</sub> )

\* Flow rate, velocity, temperature, and moisture were also determined.

All results are reported on a dry basis at STP.

Plant operating conditions have been noted in the report.

### 1.3 Licence Comparison

The following licence comparison table shows that all analytes highlighted in green are within the licence limit set by the NSW EPA as per licence 20768 (last amended on 18 April 2016).

EPA No.	Location Description	Pollutant	Units	Licence Limit	Detected Values
1	Engine 1	Nitrogen Oxides	mg/m <sup>3</sup>	57	33
		Ammonia	mg/m <sup>3</sup>	4	<0.001
2	Engine 2	Nitrogen Oxides	mg/m <sup>3</sup>	57	43
		Ammonia	mg/m <sup>3</sup>	4	<0.001

Please note that the measurement uncertainty associated with the test results was not considered when determining whether the results were compliant or non-compliant.

Refer to the Test Methods table for the measurement uncertainties.

## 2 Results

### 2.1 EPA ID No. 1 - Engine 1

Date	9/05/2023	Client	CPE Central Park Pty Ltd
Report	R014619	Stack ID	EPA ID No. 1 - Engine 1
Licence No.	20768	Location	Chippendale
Ektimo Staff	Graham Edwards	State	NSW
Process Conditions	Engine Load: 1104kW (99%), SCR Temp: 391°C		

230508

#### Sampling Plane Details

Sampling plane dimensions	430 mm
Sampling plane area	0.145 m <sup>2</sup>
Sampling port size, number & depth	1" BSP (x2), 55 mm
Duct orientation & shape	Vertical Circular
Downstream disturbance	Bend 7 D
Upstream disturbance	Bend 6 D
No. traverses & points sampled	2 8
Sample plane conformance to AS 4323.1	Ideal sampling plane

#### Stack Parameters

Moisture content, %v/v	11	
Gas molecular weight, g/g mole	28.3 (wet)	29.6 (dry)
Gas density at STP, kg/m <sup>3</sup>	1.26 (wet)	1.32 (dry)
Gas density at discharge conditions, kg/m <sup>3</sup>	0.89	

#### Gas Flow Parameters

Flow measurement time(s) (hhmm)	1245 & 1400
Temperature, °C	121
Temperature, K	394
Velocity at sampling plane, m/s	15
Volumetric flow rate, actual, m <sup>3</sup> /s	2.1
Volumetric flow rate (wet STP), m <sup>3</sup> /s	1.5
Volumetric flow rate (dry STP), m <sup>3</sup> /s	1.3
Mass flow rate (wet basis), kg/hour	6900

Gas Analyser Results		Average		Minimum		Maximum	
	Sampling time	1252 - 1352		1252 - 1352		1252 - 1352	
Combustion Gases		Concentration	Mass Rate	Concentration	Mass Rate	Concentration	Mass Rate
		mg/m³	g/min	mg/m³	g/min	mg/m³	g/min
	Nitrogen oxides (as NO₂)	33	2.7	28	2.2	41	3.3
		Concentration		Concentration		Concentration	
		% v/v		% v/v		% v/v	
	Carbon dioxide	6.5		6.4		6.6	
	Oxygen	10.3		10.2		10.3	

Ammonia		Results	
	Sampling time	1250-1350	
		Concentration	Mass Rate
		mg/m³	g/min
Ammonia		<0.001	<0.0001

## 2.2 EPA ID No. 2 - Engine 2

Date	9/05/2023	Client	CPE Central Park Pty Ltd
Report	R014619	Stack ID	EPA ID No. 2 - Engine 2
Licence No.	20768	Location	Chippendale
Ektimo Staff	Graham Edwards	State	NSW
Process Conditions	Engine Load: 970kW (87%), SCR Temp: 411°C		230508

### Sampling Plane Details

Sampling plane dimensions	430 mm
Sampling plane area	0.145 m <sup>2</sup>
Sampling port size, number & depth	1" BSP (x2), 55 mm
Duct orientation & shape	Vertical Circular
Downstream disturbance	Bend 7 D
Upstream disturbance	Bend 6 D
No. traverses & points sampled	2 8
Sample plane conformance to AS 4323.1	Ideal sampling plane

### Stack Parameters

Moisture content, %v/v	9.9	
Gas molecular weight, g/g mole	28.4 (wet)	29.6 (dry)
Gas density at STP, kg/m <sup>3</sup>	1.27 (wet)	1.32 (dry)
Gas density at discharge conditions, kg/m <sup>3</sup>	0.73	

### Gas Flow Parameters

Flow measurement time(s) (hhmm)	1125 & 1235
Temperature, °C	207
Temperature, K	480
Velocity at sampling plane, m/s	16
Volumetric flow rate, actual, m <sup>3</sup> /s	2.4
Volumetric flow rate (wet STP), m <sup>3</sup> /s	1.4
Volumetric flow rate (dry STP), m <sup>3</sup> /s	1.2
Mass flow rate (wet basis), kg/hour	6200

Gas Analyser Results	Sampling time	Average		Minimum		Maximum	
		1129 - 1229		1129 - 1229		1129 - 1229	
Combustion Gases		Concentration	Mass Rate	Concentration	Mass Rate	Concentration	Mass Rate
		mg/m <sup>3</sup>	g/min	mg/m <sup>3</sup>	g/min	mg/m <sup>3</sup>	g/min
Nitrogen oxides (as NO <sub>2</sub> )		43	3.2	37	2.7	55	4.1
		Concentration		Concentration		Concentration	
		% v/v		% v/v		% v/v	
Carbon dioxide		6.5		6.2		6.6	
Oxygen		9.9		9.9		9.9	

Ammonia	Sampling time	Results	
		1130-1230	
Ammonia		Concentration	Mass Rate
		mg/m <sup>3</sup>	g/min
		<0.001	<0.0001

### 3 Plant Operating Conditions

The below plant operating conditions have been supplied by CPE personnel.

Location	Engine Load	SCR Temperature
EPA ID No. 1 - Engine 1	1104kW (99%)	391°C
EPA ID No. 2 - Engine 2	970kW (87%)	411°C

From information received from the site operator, unless otherwise noted it is our understanding that samples were collected during normal plant operations. Unless otherwise noted all samples were collected in compliance with Ektimo's QA/QC standards.

### 4 Test Methods

All sampling and analysis performed by Ektimo unless otherwise specified. Specific details of the methods are available upon request.

Parameter	Sampling method	Analysis method	Uncertainty*	NATA accredited	
				Sampling	Analysis
Sampling points - Selection	NSW EPA TM-1 (AS 4323.1)	NA	NA	✓	NA
Flow rate, temperature & velocity	NSW EPA TM-2 (USEPA Method 2)	NSW EPA TM-2 (USEPA Method 2)	8%, 2%, 7%	NA	✓
Moisture content	NSW EPA TM-22 (USEPA Alt-Method 008)	NSW EPA TM-22 (USEPA Alt-Method 008)	19%	✓	✓
Molecular weight	NA	NSW EPA TM-23 (USEPA Method 3)	not specified	NA	✓
Dry gas density	NA	NSW EPA TM-23 (USEPA Method 3)	not specified	NA	✓
Carbon dioxide	NSW EPA TM-24 (USEPA Method 3A)	NSW EPA TM-24 (USEPA Method 3A)	13%	✓	✓
Nitrogen oxides	NSW EPA TM-11 (USEPA Method 7E)	NSW EPA TM-11 (USEPA Method 7E)	12%	✓	✓
Oxygen	NSW EPA TM-25 (USEPA Method 3A)	NSW EPA TM-25 (USEPA Method 3A)	13%	✓	✓
Ammonia	Ektimo 260	Envirolab in-house methods Inorg-093 & Inorg-057	18%	✓	✓ <sup>‡</sup>

170523

\* Uncertainties cited in this table are estimated using typical values and are calculated at the 95% confidence level (coverage factor = 2).

‡ Analysis performed by Envirolab, NATA accreditation number 2901. Results were reported to Ektimo on 29 May 2023 in report 323655.

#### 4.1 Deviations to Test Methods

Ektimo notes that Environmental Licence 20768 references the sampling and analysis of ammonia via Special Method 1 i.e. Sampling Method SCAQMD Method 207.1 or USEPA CTM-027. USEPA CTM-027 is an isokinetic method which was not possible to perform at testing locations EPA ID No. 1 or EPA ID No. 2, due to port size restrictions, out-of-stack obstructions, and positive pressure within the sampling planes at both test locations. Alternatively, Ektimo utilised NATA accredited in-house method, Ektimo 260. Ektimo 260 is a mini-impinger method, which utilises 0.1N sulfuric acid as a sampling solution and is analysed via an in-house colorimetric method (phenolate method i.e. Envirolab inorg-093 and Envirolab inorg-057) which has a sampling range of 0.003 mg/m<sup>3</sup> to 25 mg/m<sup>3</sup>.

Sampling Method SCAQMD Method 207.1 utilises 0.1N sulfuric acid as a sampling solution and is analysed via ion selective electrode (ISE). Ektimo considers utilising Ektimo 260 instead of Sampling Method SCAQMD Method 207.1 to be a minor deviation.

## 5 Quality Assurance/Quality Control Information

Ektimo is accredited by the National Association of Testing Authorities (NATA) for the sampling and analysis of air pollutants from industrial sources. Unless otherwise stated test methods used are accredited with the National Association of Testing Authorities. For full details, search for Ektimo at NATA's website [www.nata.com.au](http://www.nata.com.au).

Ektimo is accredited by NATA to ISO/IEC 17025 - Testing. ISO/IEC 17025 - Testing requires that a laboratory have adequate equipment to perform the testing, as well as laboratory personnel with the competence to perform the testing. This quality assurance system is administered and maintained by the Quality Director.

NATA is a member of APAC (Asia Pacific Accreditation Co-operation) and of ILAC (International Laboratory Accreditation Co-operation). Through mutual recognition arrangements with these organisations, NATA accreditation is recognised worldwide.

## 6 Definitions

The following symbols and abbreviations may be used in this test report:

% v/v	Volume to volume ratio, dry or wet basis
~	Approximately
<	Less than
>	Greater than
≥	Greater than or equal to
AS	Australian Standard
CEM/CEMS	Continuous emission monitoring/Continuous emission monitoring system
CTM	Conditional test method
D	Duct diameter or equivalent duct diameter for rectangular ducts
DECC	Department of Environment & Climate Change (NSW)
Disturbance	A flow obstruction or instability in the direction of the flow which may impede accurate flow determination. This includes centrifugal fans, axial fans, partially closed or closed dampers, louvres, bends, connections, junctions, direction changes or changes in pipe diameter.
EPA	Environment Protection Authority
ISC	Intersociety Committee, Methods of Air Sampling and Analysis
ISO	International Organisation for Standardisation
I-TEQ	International toxic equivalents
Lower bound	When an analyte is not present above the detection limit, the result is assumed to be equal to zero.
Medium bound	When an analyte is not present above the detection limit, the result is assumed to be equal to half of the detection limit.
NA	Not applicable
NATA	National Association of Testing Authorities
NIOSH	National Institute of Occupational Safety and Health
NT	Not tested or results not required
OM	Other approved method
STP	Standard temperature and pressure. Gas volumes and concentrations are expressed on a dry basis at 0 °C, at discharge oxygen concentration and an absolute pressure of 101.325 kPa.
TM	Test method
TOC	Total organic carbon. This is the sum of all compounds of carbon which contain at least one carbon-to-carbon bond, plus methane and its derivatives.
USEPA	United States Environmental Protection Agency
Upper bound	When an analyte is not present above the detection limit, the result is assumed to be equal to the detection limit.
95% confidence interval	Range of values that contains the true result with 95% certainty. This means there is a 5% risk that the true result is outside this range.



## **7 Appendices**

---

### ***7.1 Appendix 1: Chain of Custody***

### ***7.2 Appendix 2: Laboratory Results***

## 7.1 Appendix 1: Chain of Custody

Ektimo							
Checked at Ektimo Dispatch by: <u>CL 19/5/23</u>						Samples received in good order: <u>mm 2/5</u>	
Sample ID	Job No.	Analysis Required	Units Required	Analytical Lab	Purchase Order No.	Ektimo Contact	TAT Required (days)
N 19449	R014619	NH3	uplitre	EnviroLab	W011314	Graham Edwards	Blank NH3
N 19450	R014619	NH3	uplitre	EnviroLab	W011314	Graham Edwards	Sample A Ammonia Unit 1
N 19451	R014619	NH3	uplitre	EnviroLab	W011314	Graham Edwards	SampleB Ammonia Unit 1
N 19452	R014619	NH3	uplitre	EnviroLab	W011314	Graham Edwards	SampleA Ammonia Unit 2
N 19453	R014619	NH3	uplitre	EnviroLab	W011314	Graham Edwards	SampleB Ammonia Unit 2

Time Received: 10:30  
 Received by: mm  
 Temp. Checked: 1030  
 Cooling: 1030  
 Security: 1030

## **7.2 Appendix 2: Laboratory Results**

## **CERTIFICATE OF ANALYSIS 323655**

### **Client Details**

<b>Client</b>	Ektimo (Unanderra)
<b>Attention</b>	Administration Email
<b>Address</b>	1/251 Princes Hwy, Unanderra, NSW, 2526

### **Sample Details**

<b>Your Reference</b>	<b><u>R014619</u></b>
<b>Number of Samples</b>	5 Liquid
<b>Date samples received</b>	22/05/2023
<b>Date completed instructions received</b>	22/05/2023

### **Analysis Details**

Please refer to the following pages for results, methodology summary and quality control data.  
Samples were analysed as received from the client. Results relate specifically to the samples as received.  
Results are reported on a dry weight basis for solids and on an as received basis for other matrices.

### **Report Details**

<b>Date results requested by</b>	29/05/2023
<b>Date of Issue</b>	29/05/2023
NATA Accreditation Number 2901. This document shall not be reproduced except in full.	
Accredited for compliance with ISO/IEC 17025 - Testing. <b>Tests not covered by NATA are denoted with *</b>	

#### **Results Approved By**

Priya Samarawickrama, Senior Chemist

#### **Authorised By**

Nancy Zhang, Laboratory Manager

Miscellaneous Inorganics						
Our Reference		323655-1	323655-2	323655-3	323655-4	323655-5
Your Reference	UNITS	N19449	N19450	N19451	N19452	N19453
Type of sample		Liquid	Liquid	Liquid	Liquid	Liquid
Date prepared	-	24/05/2023	24/05/2023	24/05/2023	24/05/2023	24/05/2023
Date analysed	-	24/05/2023	24/05/2023	24/05/2023	24/05/2023	24/05/2023
Ammonia as N in impinger	mg	0.06	<0.01	0.02	0.01	0.02
Ammonia as N in water	mg/L	1.4	0.90	1.3	1.5	1.3
Volume	mL	44	9	15	9	16

Method ID	Methodology Summary
<b>Inorg-057</b>	Ammonia - determined colourimetrically, based on APHA latest edition 4500-NH3 F. Waters samples are filtered on receipt prior to analysis. Soils are analysed following a KCl extraction.
<b>Inorg-093</b>	Ammonia in impingers/filter pads using Discrete Analyser.

QUALITY CONTROL: Miscellaneous Inorganics						Duplicate		Spike Recovery %		
Test Description	Units	PQL	Method	Blank	#	Base	Dup.	RPD	LCS-W1	[NT]
Date prepared	-			24/05/2023	[NT]	[NT]	[NT]	[NT]	24/05/2023	[NT]
Date analysed	-			24/05/2023	[NT]	[NT]	[NT]	[NT]	24/05/2023	[NT]
Ammonia as N in impinger	mg	0.01	Inorg-093	<0.01	[NT]	[NT]	[NT]	[NT]	[NT]	[NT]
Ammonia as N in water	mg/L	0.005	Inorg-057	<0.005	[NT]	[NT]	[NT]	[NT]	97	[NT]

## Result Definitions

<b>NT</b>	Not tested
<b>NA</b>	Test not required
<b>INS</b>	Insufficient sample for this test
<b>PQL</b>	Practical Quantitation Limit
<b>&lt;</b>	Less than
<b>&gt;</b>	Greater than
<b>RPD</b>	Relative Percent Difference
<b>LCS</b>	Laboratory Control Sample
<b>NS</b>	Not specified
<b>NEPM</b>	National Environmental Protection Measure
<b>NR</b>	Not Reported



## Quality Control Definitions

<b>Blank</b>	This is the component of the analytical signal which is not derived from the sample but from reagents, glassware etc, can be determined by processing solvents and reagents in exactly the same manner as for samples.
<b>Duplicate</b>	This is the complete duplicate analysis of a sample from the process batch. If possible, the sample selected should be one where the analyte concentration is easily measurable.
<b>Matrix Spike</b>	A portion of the sample is spiked with a known concentration of target analyte. The purpose of the matrix spike is to monitor the performance of the analytical method used and to determine whether matrix interferences exist.
<b>LCS (Laboratory Control Sample)</b>	This comprises either a standard reference material or a control matrix (such as a blank sand or water) fortified with analytes representative of the analyte class. It is simply a check sample.
<b>Surrogate Spike</b>	Surrogates are known additions to each sample, blank, matrix spike and LCS in a batch, of compounds which are similar to the analyte of interest, however are not expected to be found in real samples.
Australian Drinking Water Guidelines recommend that Thermotolerant Coliform, Faecal Enterococci, & E.Coli levels are less than 1cfu/100mL. The recommended maximums are taken from "Australian Drinking Water Guidelines", published by NHMRC & ARMC 2011.	
The recommended maximums for analytes in urine are taken from "2018 TLVs and BEIs", as published by ACGIH (where available). Limit provided for Nickel is a precautionary guideline as per Position Paper prepared by AIOH Exposure Standards Committee, 2016.	
Guideline limits for Rinse Water Quality reported as per analytical requirements and specifications of AS 4187, Amdt 2 2019, Table 7.2	

## Laboratory Acceptance Criteria

Duplicate sample and matrix spike recoveries may not be reported on smaller jobs, however, were analysed at a frequency to meet or exceed NEPM requirements. All samples are tested in batches of 20. The duplicate sample RPD and matrix spike recoveries for the batch were within the laboratory acceptance criteria.

Filters, swabs, wipes, tubes and badges will not have duplicate data as the whole sample is generally extracted during sample extraction.

Spikes for Physical and Aggregate Tests are not applicable.

For VOCs in water samples, three vials are required for duplicate or spike analysis.

Duplicates: >10xPQL - RPD acceptance criteria will vary depending on the analytes and the analytical techniques but is typically in the range 20%-50% – see ELN-P05 QA/QC tables for details; <10xPQL - RPD are higher as the results approach PQL and the estimated measurement uncertainty will statistically increase.

Matrix Spikes, LCS and Surrogate recoveries: Generally 70-130% for inorganics/metals (not SPOCAS); 60-140% for organics/SPOCAS (+/-50% surrogates) and 10-140% for labile SVOCs (including labile surrogates), ultra trace organics and speciated phenols is acceptable.

In circumstances where no duplicate and/or sample spike has been reported at 1 in 10 and/or 1 in 20 samples respectively, the sample volume submitted was insufficient in order to satisfy laboratory QA/QC protocols.

When samples are received where certain analytes are outside of recommended technical holding times (THTs), the analysis has proceeded. Where analytes are on the verge of breaching THTs, every effort will be made to analyse within the THT or as soon as practicable.

Where sampling dates are not provided, Envirolab are not in a position to comment on the validity of the analysis where recommended technical holding times may have been breached.

Where matrix spike recoveries fall below the lower limit of the acceptance criteria (e.g. for non-labile or standard Organics <60%), positive result(s) in the parent sample will subsequently have a higher than typical estimated uncertainty (MU estimates supplied on request) and in these circumstances the sample result is likely biased significantly low.

Measurement Uncertainty estimates are available for most tests upon request.

Analysis of aqueous samples typically involves the extraction/digestion and/or analysis of the liquid phase only (i.e. NOT any settled sediment phase but inclusive of suspended particles if present), unless stipulated on the Envirolab COC and/or by correspondence. Notable exceptions include certain Physical Tests (pH/EC/BOD/COD/Apparent Colour etc.), Solids testing, total recoverable metals and PFAS where solids are included by default.

Samples for Microbiological analysis (not Amoeba forms) received outside of the 2-8°C temperature range do not meet the ideal cooling conditions as stated in AS2031-2012.



# Ektimo

[ektimo.com.au](http://ektimo.com.au)

1300 364 005

**MELBOURNE** (Head Office)

26 Redland Drive  
Mitcham  
VIC 3132  
AUSTRALIA

**SYDNEY**

6/78 Reserve Road  
Artarmon  
NSW 2064  
AUSTRALIA

**WOLLONGONG**

1/251 Princes Highway  
Unanderra  
NSW 2526  
AUSTRALIA

**PERTH**

52 Cooper Road  
Cockburn Central  
WA 6164  
AUSTRALIA

**BRISBANE**

3/109 Riverside Place  
Morningside  
QLD 4170  
AUSTRALIA